

From: [Bresnahan, Meaghan](#)
To: [Kenny Blake](#)
Cc: [Ngo, Kim](#); [Hall, Chelo](#)
Subject: FW: #20 Tank 2 Bullet and shogun indentations
Date: Monday, January 09, 2017 11:37:00 AM
Attachments: [image002.gif](#)

Hi Kenny,
Please see Jose's response below. We're still going through your other emails.
Thanks and Happy New Year,
Meaghan

From: Rodriguez, Jose
Sent: Monday, January 09, 2017 11:18 AM
To: Bresnahan, Meaghan ; Lugo-Figueroa, Jose
Cc: Baker, JohnE ; Moreno, Miguel ; Ngo, Kim
Subject: RE: #20 Tank 2 Bullet and shogun indentations
I agree with Kenny's assessment. The bullet and shot gun indentations are not a serious issue. The concern would be a long term issue because the tank steel is exposed and could start rusting/corroding and could eventually develop pin hole leaks. Waiting until they develop a plan on how to address any issues resulting from the tank inspection or until they rehabilitate the tanks would be acceptable.
Thank you,
José G. Rodriguez
(214) 665-8087
Rodriguez.jose@epa.gov

From: Bresnahan, Meaghan
Sent: Thursday, December 22, 2016 8:04 AM
To: Lugo-Figueroa, Jose <lugo-figueroa.jose@epa.gov>; Rodriguez, Jose <Rodriguez.Jose@epa.gov>
Cc: Baker, JohnE <Baker.JohnE@epa.gov>; Moreno, Miguel <Moreno.Miguel@epa.gov>
Subject: FW: #20 Tank 2 Bullet and shogun indentations

From: Kenny Blake [<mailto:kenny@cochitigolfclub.com>]
Sent: Wednesday, December 21, 2016 6:28 PM
To: Hall, Chelo <Hall.Chelo@epa.gov>
Cc: Mark Swanson <mark@cochitigolfclub.com>; Bresnahan, Meaghan <bresnahan.meaghan@epa.gov>; Baker, JohnE <Baker.JohnE@epa.gov>
Subject: #20 Tank 2 Bullet and shogun indentations
Chelo - #20 Tank 2 Bullet and shogun indentations
We are asking that this item be removed. If it cannot be removed, we are asking for an extension of time as we would need to 1. lightly grind the indentations, 2. Paint them with primer, and then 3. Paint over the primer with Tank paint.
We simply have not made this a priority and are asking for an extension until the more imperative deficiencies are dealt with.
Thanks - kb

From: Hall, Chelo [<mailto:Hall.Chelo@epa.gov>]
Sent: Wednesday, November 30, 2016 1:14 PM
To: Kenny Blake
Cc: Mark Swanson; Bresnahan, Meaghan
Subject: RE: 11 EPA Mandates

Good afternoon Kenny,

Thank you for the report you provided below. Do you have a copy of the inspection reports on the tanks? If so, would you please forward to me?

I am following up on the remainder of the significant deficiencies. Can you provide a status on the remainder of those deficiencies?

Thank you.

Chelo

From: Kenny Blake [<mailto:kenny@cochitigolfclub.com>]

Sent: Saturday, November 12, 2016 10:49 AM

To: Hall, Chelo <Hall.Chelo@epa.gov>

Cc: Kenny Blake <kenny@cochitigolfclub.com>; Mark Swanson <mark@cochitigolfclub.com>

Subject: RE: 11 EPA Mandates

Chelo - I am out of town until next Tuesday - I will prepare an update on the remaining violations. We recently had our Tanks inspected as well - Thanks - kb

From: Hall, Chelo [<mailto:Hall.Chelo@epa.gov>]

Sent: Wednesday, November 02, 2016 1:52 PM

To: Kenny Blake

Cc: Georgina Atencio

Subject: RE: 11 EPA Mandates

Hi Kenny,

I am following up on the status for the remaining significant deficiencies. Would you please provide a status for the deficiencies?

Thank you.

Chelo Hall, Environmental Engineer
EPA Region 6 Tribal Drinking Water Enforcement Coordinator
Water Resources Section (6EN-WR)
Compliance Assurance and Enforcement Division
U.S. Environmental Protection Agency, Region 6
1445 Ross Ave., Suite 1200
Dallas, TX 75154-2733
Office: (214) 665-2716
FAX: (214) 665-2168

From: Kenny Blake [<mailto:kenny@cochitigolfclub.com>]

Sent: Tuesday, September 20, 2016 3:51 PM

To: Hall, Chelo <Hall.Chelo@epa.gov>

Cc: Georgina Atencio <georgina@cochitigolfclub.com>

Subject: RE: 11 EPA Mandates

Ok I understand and we will address immediately... but are your sure some of these are not the Pueblo's as item 17 addresses the Buffalo and Village water storage tanks. Those are describing the Pueblo's water tanks.

Regardless - we will begin addressing the additional issues listed.

Respectfully - kb

From: Hall, Chelo [<mailto:Hall.Chelo@epa.gov>]

Sent: Tuesday, September 20, 2016 1:36 PM

To: Kenny Blake

Subject: RE: 11 EPA Mandates

Kenny, the copy of the inspection report you received contained only 11 deficiencies; however, the copy I sent the Governor contained 21. I am so sorry for the confusion. The copy machine did not copy all of the pages (significant deficiencies) for some reason. Therefore, I am sending the full pages

to the Corrective Compliance Plane for the Cochiti Lake Water System.
I must say that you really addressed many of the issues there! Good job!
If you have questions, please give me a call.

Chelo

214-665-2716

From: Kenny Blake [<mailto:kenny@cochitigolfclub.com>]

Sent: Friday, August 19, 2016 3:54 PM

To: Hall, Chelo <Hall.Chelo@epa.gov>

Subject: 11 EPA Mandates

Chelo - Please find attached the 11 EPA Mandates I will be referencing as I send attached pictures showing their resolution - Thanks - kb

Kenny Blake PGA | Cochiti Community Development Corporation
Chief Executive Officer

5200 Cochiti Highway
Cochiti Lake, NM 87083

T (505) 465-2210 x 11 | **F** (505) 465-0160

kenny@cochitigolfclub.com

www.cochitigolfclub.com | *Professional. Precision. Performance.*

CONFIDENTIALITY NOTICE

This e-mail and any attachments are for the sole use of the intended recipients and contain information that may be confidential or legally privileged. If you have received this e-mail in error, please notify the sender by reply e-mail and delete the message. Any disclosure, copying, distribution, or use of this communication by someone other than the intended recipient is prohibited.